



STANDARDS DIVISION

OTTAWA, July 9, 1957.

TYPE APPROVALPACKARD TYPE "FH-15" VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "FH-15" Voltage Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage 7200/12470Y
 Secondary Voltage 120
 Accuracy Rating 0.3WXYZ, ZZ
 Insulation Class 15 KV
 Frequency 60 cycles
 Style Outdoor oil-filled.

Description: Details of transformer are:- Lock wound core, outdoor oil-filled and insulated for Y connection on 12470 volts. A connection diagram is shown on the nameplate. Polarity is indicated by H_1 and X_1 painted in white on the tank adjacent to the appropriate terminals. One of the low-voltage bushings is a dummy and there is no connection to it. The design and general appearance is similar to the type "FH-8.7" approved under Circular SD-EA.254, July 12, 1956.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-663

