



TRADE AND COMMERCE
CANADA

SD-EA.319

STANDARDS DIVISION

OTTAWA, October 24, 1957.

TYPE APPROVALPACKARD TYPE "BF-X SPECIAL" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "BF-X Special" Single-Secondary Voltage Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Rated Voltage 550-110, or 575-115, or 600-120
 Volt-Amperes 200 VA
 Accuracy Rating ASA 0.3WXY, 0.6Z*
 Thermal Rating 900 VA at 55°C. rise
 Insulation Class 1.2 KV
 Frequency 60 cycles
 Style Dry Indoor

* shown on nameplate.

Description: The appearance and general design are essentially the same as the type "BF-X Special" described under Circulars SD-EA.160, October 22, 1954 and SD-EA.169, December 21, 1954, except for the ratio.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-696

