



TRADE AND COMMERCE  
CANADA

SD-EA. 324

## STANDARDS DIVISION

OTTAWA, December 6, 1957.

TYPE APPROVALPACKARD TYPE "B-X SPECIAL" VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "B-X Special" Single Secondary Voltage Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

|                        |   |
|------------------------|---|
| Rated Voltage .....    | 2400/4160Y-120 or comparable ratings with secondary voltages of 110 and 115 |
| Volt-Amperes .....     | 200   |
| Accuracy Rating* ..... | 0.3WXY, 0.6Z  |
| Insulation Class ..... | 5KV   |
| Frequency .....        | 60 cycles   |
| Style .....            | Dry Indoor  |

\* shown on nameplate.

Description: The appearance and general design are essentially the same as the type "B-X" approved under Circular SD-EA.169, December 21, 1954, except that the insulation class has been increased to allow a 5KV class rating.

*E. F. Power*

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

*R. W. MacLean*  
R. W. MacLean,  
Director,  
Standards Division.

Ref: A-610

