

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, December 16, 1957.

TYPE APPROVALWESTINGHOUSE TYPE "EMR" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "EMR" Current Transformers, manufactured by the Westinghouse Electric Corporation, Sharon, Pa., and distributed in Canada by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus:

Primary Voltage Rating	600 volts
Current Rating	400-5 amperes
Accuracy Class	0.3B0.1, 0.3B0.2*
Frequency	60 cycles
Continuous Current Rating	200%

* shown on nameplate.

Description: Except for the higher current rating, these transformers are of the same design and appearance as those described and approved under Circular SD-EA.309, August 19, 1957.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-655A

