

TRADE AND COMMERCE
CANADA

SD-EA.329

STANDARDS DIVISION

OTTAWA, January 9, 1958.

TYPE APPROVALPACKARD TYPE "T" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "T" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 1000, 1200, and 1500 amperes
 Secondary Current 5 amperes
 Voltage Rating 600
 Accuracy Rating -
 (25 and 60 cycles) 0.6B0.1, B0.5^{*}, B0.9, 2xB0.9, B2.0
 Frequency 25 and 60 cycles
 Style Dry Indoor, Through-Type

^{*} 0.6B0.5 shown on nameplate.

Description: These transformers are identical to the type "T" previously approved for 60 cycles under Circular SD-EA.325 of December 16, 1957. This circular extends the approval to include their use on 25 cycles.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-711A

