



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, January 22, 1958.

TYPE APPROVALPIONEER TYPE "FCP" VOLTAGE TRANSFORMERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "FCP" Voltage Transformers, manufactured by the Pioneer Electric Limited, No. 1 Rockwood Place, Fort Garry, Winnipeg 9, Manitoba.

## Rating of Apparatus:

Primary Voltage ..... 2400 volts  
 Secondary Voltage ..... 120 volts  
 Burden Rating ..... 75VA at 0.85 p.f.  
 Accuracy Classification ..... 0.3WX, 1.2Y  
 Frequency ..... 60 cycles.

Description: The type "FCP" is a folded core voltage transformer, mounted in a compound-filled tank. It is intended for use in switchgear, being usually mounted in a withdrawable drawer.

The transformer may be supplied with or without a fuse in one primary lead. When a fuse is used, a dummy bushing is mounted on top of the tank to support it. The illustrations on the back of the circular show the terminal arrangements in each case.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-635



## PIONEER TYPE "FCP" VOLTAGE TRANSFORMER



