



STANDARDS DIVISION

OTTAWA, March 18, 1958.

TYPE APPROVALCANADIAN WESTINGHOUSE TYPE "CTO" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "CTO" current transformer, manufactured by the Canadian Westinghouse Company Limited, Toronto, Ontario.

Rating of Apparatus:

Primary Current	5 amperes
Secondary Current	5 amperes
Voltage Ratings	5 KV, 8.7 KV, 15 KV
Accuracy Ratings	ASA 0.3B0.1, B0.2, B0.5, 0.6B2.0
Wire	2
Frequency	25 to 60 cycles
Style	Dry Outdoor

Description: This approval extends the ratings approved in Circular SD.EA.144 of March 11, 1954 to include the 5 ampere primary rating. The transformer approved herein is identical in all respects, except for rating, to those previously approved.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-346

