


 TRADE AND COMMERCE  
 CANADA

SD-PA.352b

## STANDARDS DIVISION

OTTAWA, July 10, 1958.

TYPE APPROVAL
CANADIAN WESTINGHOUSE TYPE "DAH"  
COMBINATION THERMAL DEMAND-ENERGY METER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "DAH" Single-Phase Combination Thermal Demand-Energy Meter, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

## Rating of Apparatus:

Current Range .....	0.75-100 amperes
Volts .....	230 or 240
Wire .....	3
Full Scale Demand .....	24 KW
Scale Range .....	0-1200
Multiplier .....	20
K <sub>h</sub> .....	3.6
Frequency .....	60 cycles

Description: This meter is identical to the type "DSH" meter previously approved under Circular SD-PA.352a, April 24, 1958, except that it is designed for 'A' base mounting.

 E. F. Power,  
 Assistant Director (DSG),  
 Standards Division.

R. W. Haslam,  
 Director,  
 Standards Division.

Ref: A-745A

