



## STANDARDS DIVISION

OTTAWA, May 30, 1958.

TYPE APPROVALPACKARD TYPE "MC-15" VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MC-15" Voltage Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Voltage ..... 7200/12470Y  
 Secondary Voltage ..... 120  
 Accuracy Rating ..... 0.3WXYZ, ZZ  
 Insulation Class ..... 15KV  
 Frequency ..... 60 cycles  
 Style ..... Outdoor oil-filled.

Description: The type "MC-15" voltage transformer is intended for use in metering units. It consists of the core and coil assembly of the type "FH-15" approved under Circular SD-EA.302, July 9, 1957.

*E. F. Power*

E. F. Power,  
 Assistant Director (E&G),  
 Standards Division.

*R. W. MacLean*  
 R. W. MacLean,  
 Director,  
 Standards Division.

Ref: A-518L

