


 TRADE AND COMMERCE
 CANADA

SD-EA.363

STANDARDS DIVISION

OTTAWA..... June 23, 1958.....

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current	30 amperes
Secondary Current	5 amperes
Voltage Rating	2.5 KV
Accuracy Rating - at 60 cycles	0.3B0.1, 0.3B0.5 [*] , 0.3B0.9, 0.6B2.0
- at 25 cycles	0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0
Frequency	25-60 cycles
Style	Dry Indoor

^{*} shown on nameplate.

Description: The 30-ampere primary rating approved herein is identical in all respects to the ratings previously approved in SD-EA.229 of February 1, 1956. This approval, therefore, extends the previous approval to include the 30-ampere rating.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

H. W. MacLean,
 Director,
 Standards Division.

Ref: A-458C

