

TRADE AND COMMERCE
CANADA

SD-EA.365

STANDARDS DIVISION

OTTAWA, July 3, 1958.

TYPE APPROVALPACKARD TYPE "T" CURRENT TRANSFORMERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "T" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current	2000 and 3000 amperes
Secondary Current	5 amperes
Voltage Rating	600
Accuracy Rating - 2000-5 Ratio ...	0.3B0.1, B0.5*, B0.9, 2xR0.9, 0.6B2.0
- 3000-5 Ratio ...	0.3B0.1, B0.5*, B0.9, 2xR0.9, B2.0
Frequency	25 to 60 cycles
Style	Dry Indoor, Through-Type


* 0.3B0.5 shown on nameplate.

Description: Except for the higher current ratings these transformers are to the same design as those approved on Circulars SD-EA.325, December 16, 1957 and SD-EA.329, January 9, 1958.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-711B



PACKARD TYPE "T" CURRENT TRANSFORMER

