

TRADE AND COMMERCE  
CANADA

SD-EA.371

## STANDARDS DIVISION

OTTAWA, September 10, 1958.

TYPE APPROVALFERRANTI-PACKARD TYPE "VLI" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "VLI" Voltage Transformer, manufactured by the Ferranti-Packard Electric Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Voltage ..... 115  
Secondary Voltage ..... 115  
Accuracy Rating ..... ASA 1.2 W  
Insulation Class ..... 600 volts  
Frequency ..... 60 cycles  
Style ..... Dry Indoor.

Description: The transformer approved herein is identical in design to the type "VLI" transformers previously approved on Circular SD-EA.201 of June 30, 1955 for the Packard Electric Company Limited.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-434 1}

