

TRADE AND COMMERCE
CANADA

SD-EA.372

STANDARDS DIVISION

OTTAWA, September 11, 1958.

TYPE APPROVALSANGAMO "GENEVA"-TYPE CYCLOMETER REGISTER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.


Apparatus Approved: "Geneva"-type Cyclometer Register for use on type "NB-" polyphase meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus: All approved ratings of types "NBA", "NBAP", "NBP", "NBS", "NBDAP", "NBDP" and "NBDS".

Description: This is a similar type of cyclometer register to that approved under NRC-6 of September 23, 1930, for use on "S-3" meters. However, the register has been modified to provide a greater spacing from the meter spindle and a change of register ratios to match the above types of meters.

E. F. Power

(E. F. Power),
Assistant Director (E&G),
Standards Division.



(R. W. MacLean),
Director,
Standards Division.

Ref: A-776

SANGAMO "GENEVA"-TYPE CYCLOMETER REGISTER

