



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, October 22, 1958.

TYPE APPROVAL

CANADIAN WESTINGHOUSE TYPE "DS" WATTHOUR METER  
(50-CYCLE)

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "DS" 50-cycle, single-phase Watthour Meter, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

## Rating of Apparatus:

Normal Range ..... 0.75-100 amperes  
Voltage ..... 230 or 240  
Wire ..... 3  
Frequency ..... ~~60~~<sup>50</sup> cycles  
K<sub>h</sub> ..... 3.6

Description: The construction and electrical characteristics of the type "DS" 50-cycle meters are the same as the type "DS" 60-cycle meters, approved under Circular SD-EA.238, April 10, 1956 except that the number of turns on the potential coil and the material used in the quadrature loop are different.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-545B

