



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, December 9, 1958.

TYPE APPROVALFERRANTI-PACKARD TYPE "T" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.


Apparatus Approved: Type "T" Current Transformer, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current ..... 2500 amperes  
 Secondary Current ..... 5 amperes  
 Voltage Rating ..... 600 volts  
 Accuracy Rating ..... 0.3B0.1, B0.5\*, B0.9, 2xB0.9, 0.6B2.0  
 Frequency ..... 25 to 60 cycles  
 Style ..... Dry Indoor, Through-Type.

\* marked on nameplate.

Description: Except for the primary current rating, the transformer approved herein is identical in design to the ratings approved in Circular SD-EA.365 of July 3, 1958 for the Packard Electric Company Limited, the accuracy rating being the same as that for the 2000-5 ampere rating.

  
 R. W. MacLean,  
 Director,  
 Standards Division.

*E. F. Power*

E. F. Power,  
 Assistant Director (E&G),  
 Standards Division.

Ref: A-711B

