

TRADE AND COMMERCE
CANADA

SD-EA.383

STANDARDS DIVISION

OTTAWA, December 15, 1958.

TYPE APPROVALSANGAMO TYPE "MV-6" 3-WIRE CURRENT TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MV-6" 3-Wire Current Transformer, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Primary Currents 50, 100, 150, 200, 300 and 400 amperes
 Secondary Current 5 amperes
 Accuracy Rating 0.3B0.1, 0.3B0.2*, 0.6B0.5
 Rated Voltage 0.6 KV
 Wire 3
 Frequency 60 cycles
 Style Indoor type.

* accuracy stamped on nameplate.

Description: This transformer is the 3-wire, 60-cycle counterpart of the type "MV-6" 2-wire transformer approved under Circular SD-EA.379, November 14, 1958. It will supersede the present type "LV" 3-wire transformer.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-756A

.....
.....

.....

.....

SANGAMO TYPE "MV-6" 3-WIRE CURRENT TRANSFORMER



