

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, January 22, 1959.

TYPE APPROVALEASTERN POWER DEVICES TYPE "T"
DOUBLE-RATIO CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "T" Current Transformers, manufactured by Eastern Power Devices Limited, Port Credit, Ontario.

Rating of Apparatus:


Primary Current 3000/2000 amperes
Secondary Current 5 amperes
Voltage Class 5 KV for types "T-2" and "T-3"
600 volts for types "T-5" and "T-6"

Accuracy Rating:

For 2000-amp. primary 0.3B0.1, B0.5, B0.9*, B1.0, B2.0
For 3000-amp. primary 0.3B0.1, B0.5, B0.9*, B1.0, 0.6B2.0
Frequency 60 cycles
Style Indoor

* stamped on nameplate.

Description: These transformers are of the same design as those approved under Approval Circular SD-EA.291, April 4, 1957, except that they have a double ratio. The illustration for the type "T" was inadvertently interchanged with that of the type "C" and consequently is shown on the back of Circular SD-EA.290.


R. W. MacLean,
Director,
Standards Division.


E. F. Power,
Assistant Director (E&G),
Standards Division.

Ref: A-576A

