

TRADE AND COMMERCE  
CANADA

SD-EA.397

## STANDARDS DIVISION

OTTAWA, April 8, 1959.

TYPE APPROVALENGLISH ELECTRIC CANADA TYPE "U"  
INSTRUMENT VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "U" Instrument Voltage Transformer, manufactured by English Electric Canada, a Division of John Inglis Co. Limited, St. Catharines, Ontario.

## Rating of Apparatus:


Primary Voltage .....	4800/2400
Secondary Voltage .....	120 volts
Accuracy Class .....	0.6Z
B.I.L. ....	75 KV
Wire .....	2
Phase .....	1
Frequency .....	60 cycles
Style .....	Outdoor, Oil-Filled.

Description: This voltage transformer is a distribution type, oil-filled, designed for outdoor service. The primary is wound in two sections, and internal links below the oil level may be changed to series or parallel for primary voltages of 4800 or 2400 respectively. A connection diagram is shown on the nameplate. Polarity is also indicated by "H1" and "X1" painted on the sides of the tank.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-810



SD-EA.397

ENGLISH ELECTRIC CANADA TYPE "U"  
INSTRUMENT VOLTAGE TRANSFORMER

