

TRADE AND COMMERCE  
CANADA

SD-EA.401

## STANDARDS DIVISION

OTTAWA, April 27, 1959.

TYPE APPROVALHYDRO-ELECTRIC POWER COMMISSION  
TYPE "H8.7" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "H8.7" Voltage Transformer, manufactured or modified expressly to specifications of The Hydro-Electric Power Commission of Ontario, 620 University Avenue, Toronto 2, Ontario, by Canadian Westinghouse Company Limited, London, Ontario.

## Rating of Apparatus:

Primary Voltage Rating .....	4800/2400 volts
Secondary Voltage Rating .....	120 volts
Insulation Class .....	8.7 KV
Accuracy Rating .....	0.3Y 0.6Z
Frequency .....	60 cycles
Style .....	Oil-insulated, Outdoor.

Description: These voltage transformers are oil-insulated, 3 KVA distribution transformers, manufactured or modified to Ontario Hydro specifications by the Canadian Westinghouse Company Limited, London, Ontario. Polarity is indicated by  $H_1$  and  $X_1$  painted prominently on the tank adjacent to the appropriate terminals.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-785



HYDRO-ELECTRIC POWER COMMISSION  
TYPE "H8.7" VOLTAGE TRANSFORMER



