



TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

OTTAWA December 8, 1959.

TYPE APPROVAL

ENGLISH ELECTRIC CANADA TYPE "U"
INSTRUMENT VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "U" Instrument Voltage Transformer, manufactured by English Electric Canada, a Division of John Inglis Co. Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Voltage 7200
 Secondary Voltage 120
 Accuracy Class * 0.3VX, 0.6Z
 BIL 25 KV
 Wire 2
 Phase 1
 Frequency 60 cycles
 Style Outdoor, oil-filled.

* 0.3Y, 0.6Z marked on nameplate.

Description: This voltage transformer is in a distribution-type case, oil-filled, designed for outdoor service. It is similar in design and appearance to that approved under Circular SD-EA.397 of April 8, 1959. A connection diagram is shown on the nameplate, and the polarity will be indicated by the letters "H₁" and "X₁" painted on the side of the tank adjacent to the corresponding terminals.


 R. W. MacLean
 Director,
 Standards Branch.



E. F. Power,
 Assistant Director (E&G),
 Standards Branch.

Ref: A-810A

1

2

3