

DEPARTMENT OF



TRADE AND COMMERCE
CANADA

S-EA.440

STANDARDS BRANCH

OTTAWA, March 21, 1960.

TYPE APPROVAL

PIONEER TYPE "FCP" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "FCP" Voltage Transformer, manufactured by Pioneer Electric Limited, No.1 Rockwood Place, Fort Garry, Winnipeg 9, Manitoba.

Rating of Apparatus:

Primary Voltage 360, 240
Secondary Voltage 120
Burden Rating 75 VA at 0.85 p.f.
Accuracy Classification 0.3M, 1.2Y
Frequency 60 cycles.

Description: Except for the ratios, these transformers are identical in appearance and construction to those listed under Circular SD-EA.406 of June 1, 1959.

E. F. Power

E. F. Power,
Assistant Director (E2G),
Standards Branch.

R. W. MacLean

R. W. MacLean,
Director,
Standards Branch.

Ref: A-636H

