

TRADE AND COMMERCE  
CANADA

STANDARDS BRANCH

OTTAWA August 15, 1960.

TYPE APPROVALFERRANTI-PACKARD TYPE "LD" 2-WIRE CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "LD" 2-Wire Current Transformers, manufactured by Ferranti-Packard Electric Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Currents .....	5, 10, 15, 20, 25, 40, 50, 75, 100, 150, 200, 300 and 600 amperes
*Secondary Current .....	5 amperes
Voltage Rating .....	600 volts
Accuracy Rating .....	0.6B0.1, 0.6B0.2
Frequency .....	25 cycles
Style .....	Indoor
*R.F. (rating factor) .....	1.5

\* The R.F. of 1.5 indicates that these transformers are approved for use in situations where the secondary current may reach 7.5 amperes. The accuracy rating under this condition remains unchanged.

Description: The transformers approved herein are identical to the transformers previously approved under Circular S-EA.463 of July 19, 1960 except for the frequency rating (25 cycles) and corresponding accuracy rating.

E. F. Power,  
Assistant Director (E&G),  
Standards Branch.

R. W. MacLean,  
Director,  
Standards Branch.

Ref: A-866

