



TRADE AND COMMERCE
CANADA

STANDARDS BRANCH

OTTAWA February 15, 1962.

TYPE APPROVAL

SANGAMO TYPE "MP-6" VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "MP-6" Voltage Transformer, manufactured by Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Primary Voltage	600, 480, 240, 120 volts
Secondary Voltage	120 volts
Accuracy Class	0.3W and 0.6X
Insulation Class	0.6KV
Thermal Rating	200 volt-amperes
Frequency	60 cycles
Style	Indoor
Wire	2
Phase	1

Description: The type "MP-6" voltage transformer approved herein is identical to the type "MP-6" previously approved in Circular S-EA.479 of October 26, 1960 except for 120 volts secondary voltage and 600, 480, 240 and 120 volts primary voltage.

E. F. Power

E. F. Power,
Chief, Electricity & Gas Division,
Standards Branch.

R. W. MacLean
R. W. MacLean,
Director,
Standards Branch.

Ref: A-878