



TRADE AND COMMERCE  
CANADA

STANDARDS BRANCH

OTTAWA, November 14, 1962.

TYPE APPROVAL

CANADIAN GENERAL ELECTRIC TYPE "PV-5"  
VOLTAGE TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S.1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "PV-5" Voltage Transformer, manufactured by the Canadian General Electric Company Limited, Toronto 4, Ontario.

Rating of Apparatus:

- Primary Voltage ..... 575, 460 volts
- Secondary Voltage ..... 115 volts
- Accuracy Class ..... 0.3WXY; 1.2Z
- Voltage Class ..... 5 Kv
- Wire ..... 2
- Phase ..... 1
- Frequency ..... 60 cycles
- Style ..... Dry Indoor.

cription: These voltage transformers are designed for indoor service and are of wound primary construction with single primary ratings and a high grade silicon steel in the core. The entire core and coil assembly is impregnated with, and moulded in, a thermosetting plastic material said to be of high mechanical and electrical strength. Primary and secondary terminals are fixed studs, moulded in the plastic.

This is an extension of Circular SD-EA.184 of April 20, 1955, to include two additional ratios.

*E. F. Power*

E. F. Power,  
Chief, Electricity and Gas Division,  
Standards Branch.

*R. W. MacLean*  
R. W. MacLean,  
Director,  
Standards Branch.

Ref: A-719B

