

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

Files: SE-85-2-1 and SL-100-882-0

OTTAWA, December 8, 1965.

TO: DISTRICT INSPECTORS OF ELECTRICITY AND GAS

Re: Modifications to Canadian Westinghouse Types
"D2A" and "D3S" Single-Phase Watthour Meters

This is to advise you that the voltage coil used in all capacities and voltage ratings of the types "D2A" and "D3S" single-phase watthour meters (except the 120/240 volt, 2/3 wire - SD-EA.307) is now produced in a moulded form.

The use of the power factor device receiving approval under S-EA.584 has now been extended to all capacities of the "D2A" and "D3S" watthour meters.

The voltage coil disconnect links using screws for fastening will be replaced with a spring- or snap-action type.

This is your authority to verify such "D2A" and "D3S" watt-hour meters incorporating any or all of the above modifications as may be presented.


(K. Cryer)

Chief, Electricity and Gas Division.

EAW/mee