


 TRADE AND COMMERCE
 CANADA

S-EA.596

STANDARDS BRANCH

OTTAWA, September 11, 1963.

Type ApprovalSangamo Types "CJ3A" and "CJ3S" Single-Phase Watthour Meters

The apparatus specified herein have been duly approved by the Standards Branch under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CJ3A" and "CJ3S" Single-Phase Watthour Meters, manufactured by Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus	#	0	0	0
* Current Range (amperes)	0.12-10	0.5-50	0.75-100	2.0-200
* Voltage	115 or 230	115	115 or 230	115 or 230
Wire	2 or 3	2	2 or 3	2 or 3
Frequency	50 cycles for all ratings			
Disc constant	0.3 for 115V 0.6 for 230V	1.5	3 for 115V 6 for 230V	6 for 115V 12 for 230V
Register Ratios:				
Clock type 4-dial x 1	333-1/3 for 115V 166-2/3 for 230V	66-2/3	33-1/3 for 115V 16-2/3 for 230V	16-2/3 for 115V --
Clock type 4-dial x 10	--	--	166-2/3 for 230V	166-2/3 for 115V
Clock type 5-dial x 1	--	--	16-2/3 for 230V	83-1/3 for 115V 16-2/3 for 115V 8-1/3 for 230V
Cyclometer type x 1	416-2/3 for 115V 208-1/3 for 230V	83-1/3	41-2/3 for 115V 20-5/6 for 230V	20-5/6 for 115V --
Cyclometer type x 10	--	--	208-1/3 for 230V	208-1/3 for 115V 104-1/6 for 230V
Type of Base	A and S	A and S	A and S	S for 115V A and S for 230V

* Meters with 120 volt ratings, or multiples thereof, are also approved for all capacities.

Transformer type. Other ratings are self-contained

