



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH



OTTAWA February 28, 1966.

NOTICE OF APPROVAL

FOR

CANADIAN ALLIS-CHALMERS TYPE "CDD" CURRENT TRANSFORMERS

Apparatus

Primary Current	3000 amperes
Secondary Current	5 amperes
Accuracy Class	0.3B0.1, B0.2, B0.5, B0.9, B(2 x 0.9), B1.0, B2.0
Voltage Insulation	
Class	5 Kv
Phase	1
Wire	2
Frequency	60 cycles
R.F. (rating factor)	1.0

* accuracy marked on nameplate is 0.3B0.1, B0.5, B2.0

Description

These transformers are ring type and have an outer insulation of plastic tape.

Primary polarity is indicated by a label marked H1. The secondary terminals protrude radially from the outside of the transformer and are marked X1 and X2. A third terminal marked X0 is a shield and is intended to be grounded.

The paper nameplate attached to the outer surface of the transformer is protected by an oil and waterproof coating.

Approval granted to Canadian Allis-Chalmers Limited,
Lachine, Quebec.

W.J.S. Fraser
W.J.S. Fraser,
Chief, Standards Laboratory,
Standards Branch.

K. Cryer
K. Cryer,
Chief, Electricity & Gas Division,
Standards Branch.

Ref: SL-100-76E

CANADIAN ALLIS-CHALMERS TYPE "CDD" CURRENT TRANSFORMERS

