



DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS BRANCH

T-8

OTTAWA January 21, 1966.

NOTICE OF APPROVAL

FOR

FERRANTI-PACKARD TYPE "3LD" 3-WIRE CURRENT TRANSFORMERS

Apparatus

Primary currents	25/25, 50/50, 75/75, 100/100, 150/150, 200/200, 300/300, 400/400, 600/600, 800/800, 1000/1000 and 1200/1200 amperes
Secondary Current	5 amperes*
Voltage Rating	600 volts
Accuracy Rating	
25/25 to 400/400	0.3B0.1, B0.2; 0.6B0.5 <sup>#</sup>
600/600 to 1200/1200	0.3B0.1, B0.2, B0.5; 0.6B0.9 <sup>#</sup>
Wire	3
Frequency	60 cycles
R.F. (rating factor)	°1.0 (1200/1200-5), 1.25 (1000/1000-5), 1.5 all others
Style	Dry, indoor

\* With rated current in both primary windings

# Accuracy marked on nameplate 0.3 B0.5

° The accuracy remains unchanged up to 7.5 amperes secondary current

...../2

1