



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-10-2

Ottawa, April 6, 1977

SANGAMO TYPE "MV-6" 2-WIRE CURRENT TRANSFORMERS

This Notice constitutes an addition to T-10-1 which remains in effect.

It covers an additional rating of 2.5-5 amperes for the subject transformers.

The accuracy rating at 60 Hz is 0.3B0.2 and the rating factor is 1.5.

Approval granted to:

Sangamo Company Ltd.,
Toronto, Ontario.

J.L. Armstrong, P. Eng.
Chief, Standards Laboratory,
Metrology and Laboratory Services.

D.L. Smith, P. Eng.,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: G6565-S2-32