



**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-10-3

Ottawa, November 10, 1977

SANGAMO TYPE "MV-6" 2-WIRE CURRENT TRANSFORMERS

Primary Currents	5, 10, 15, 20, 25, 30, 40, 50, 75, 100, 150, 200, 250, 300, 400, 500, 600, 800, 1000 and 1200 A
Secondary Current	5 A
Accuracy Rating at 60 Hz	0.3 BO.2* 0.3 BO.9*
RF (rating factor)	
5 to 500 A incl.	1.5
600 A	1.33 new design    1.5 older design
800 A	1.5
1000 A**	1.5 new design    1.2 older design
1200 A**	1.25 new design   1.0 older design
Frequency	60 Hz
Wire	2
Style	Dry, Indoor

\* Transformers manufactured prior to February 18, 1966 are marked "accuracy at 60 Hz 0.3 BO.2", and those manufactured subsequently, are marked "accuracy at 60 Hz 0.3 BO.9."

\*\* The RF marked on the nameplate distinguishes the new design from the older.

This is an addition to Notice of Approval T-10-2 to permit the extension of the RF for the 1000-5 A and the 1200-5 A ratings from 1.2 to 1.5 and from 1.0 to 1.25 respectively.

Approval granted to:

Sangamo Company Ltd.,  
Toronto, Ontario.

A handwritten signature in cursive script, appearing to read "D.L. Smith".

D.L. Smith, P.Eng.  
Chief, Electricity and Gas Division,  
Legal Metrology Branch.

Ref: G-6565-S2-32