



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-14-1

OTTAWA April 14, 1975

FERRANTI-PACKARD TYPE CS -15 METERING UNITS

This Notice constitutes an addition to T-14 which remains in effect.

Approval is hereby granted for the use of type EH-15 and EHR-15 current transformers in type CS -15 metering units.

The type EH-15 is the same as conventional F.P. 50/100-5A with tapped secondary except that one half of the secondary winding will be omitted. Current rating is 50-5A. Accuracy rating is 0.3B0.9, 0.6B2.0.

The type EHR-15 uses a ring core and toroidal winding. Current rating is 25-5A. Accuracy rating is 0.3B1.8.

Approval granted to:

Ferranti-Packard Ltd.,
St. Catharines, Ontario.

J.L. Armstong,
Chief, Standards Laboratory,

D.L. Smith,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: 1145-57/F2-517