



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

T-14-2

Ottawa, August 13, 1975

FERRANTI-PACKARD TYPE CSS-15 METERING UNITS

This Notice constitutes an amendment to T-14-1 which is hereby revoked.


Approval is hereby granted for the use of type EH-15 and EHR-15 current transformers in type CSS-15 metering units.


The type EH-15 is the same as a conventional F.P. 50/100-5A with tapped secondary except that one half of the secondary winding will be omitted. Current rating is 50-5A. Accuracy rating is 0.3B0.9, 0.6B2.0.

The type EHR-15 uses a ring core and toroidal winding. Current rating is 25-5A. Accuracy rating is 0.3B1.8.

Approval granted to:

Ferranti-Packard Ltd.,
St. Catharines, Ontario.


J.L. Armstrong,
Chief, Standards Laboratory,
Metrology and Laboratory Services.


D.L. Smith,
Chief, Electricity and Gas Division,
Metrology and Laboratory Services.

Ref: GL 1145-57/F2-387