



Consumer and  
Corporate Affairs  
Canada

Legal Metrology

Consommation  
et Corporations  
Canada

Métrologie Légale

T-14-4

Approval No. d'approbation

Ottawa

DEC 14 1982

## NOTICE OF APPROVAL – AVIS D'APPROBATION

### FERRANTI-PACKARD Types CSR5, CSR8-7 and CSR15 Metering Units

This Notice constitutes an addition to T-14 which remains in effect.

Company: Ferranti-Packard Transformers Limited  
P.O. Box 548  
St. Catharines, Ontario  
L2R 6W9

Manufacturer: Ferranti-Packard

Type of Device: Metering unit.

Description: The type CSR 15 metering unit is a re-design of the type CSS15 metering unit from a rectangular tank to a circular tank.

Component current transformers will be type KC15 or RY15, 5/10-5A to 400/800-5A, accuracy rating 0.3B0.9, RF 1.5.

The voltage transformers will be type MC15, 14550GrdY/8400-120 volts, accuracy rating 0.3ZZ.

Re-design of the tank only also includes former types CSS-5 and CSS8-7.

### Compteurs CSR5, SCR8-7 et CSR15

### FERRANTI-PACKARD

Le présent avis complète l'avis T-14 qui demeure en vigueur.

Société: Ferranti-Packard Transformers Limited  
P.O. Box 548  
St. Catharines, Ontario  
L2R 6W9

Fabricant: Ferranti-Packard

Appareil: Compteur.

Description: Le compteur de type CSR15 est une modification du compteur de type CSS15 qui avait un réservoir rectangulaire et qui est maintenant circulaire.

Les transformateurs d'intensité utilisés avec les compteurs seront de type KC15 ou RY 15, de 5/10A à 400/800-5A, présentant une précision nominale de 0.3B0.9 et un facteur de surcharge de 1.5.

Les transformateurs de tension utilisés seront de type MC15, étoile à la terre 1455/8400-120 volts, présentant une précision nominale de 0.3ZZ.

La modification du réservoir seulement renferme aussi les types précédent CSS5 et CSS8-7.

.../2

- 2 -

Conditions: The apparatus specified herein has been duly approved under the provisions of the Electricity Inspection Act, R.S.C. 1970, chapter E-4 and the Electricity Meter Regulations C.R.C. 1978, chapter 561.

Reference No.: G6565-F2-32

Chief  
Legal Metrology Laboratories

Condition d'approbation: L'appareil visé a été dûment approuvé en vertu des dispositions de la Loi sur l'inspection de l'électricité S.R.C. 1970, chapitre E-4, et du règlement sur les compteurs électriques C.R.C.c., 1978, chapitre 561.

No. de référence: G6565-F2-32

Chef  
Laboratoires de la Métrologie légale

  
W.R. Virtue

DEC 14 1982