



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-15-1

OTTAWA October 18, 1973

CANADIAN WESTINGHOUSE TYPE "RCT-15" CURRENT TRANSFORMERS

This approval cover additions to the ratings embraced under T-15. T-15 remains in effect.

Apparatus

Primary Currents	2500 and 4000 amperes
Secondary Current	5 amperes
Accuracy Rating at 60 HZ	
Both Ratios	0.3B0.1, B0.2, B0.5, B0.9, B1.0, B1.8, B2.0*
Frequency	60 HZ
R.F. (rating factor)	1.33
Wire	2
Style	Indoor
Nominal Voltage Class	15 Kv

* 0.3B2.0 marked on the nameplates

Approval granted to:

Canadian Westinghouse Company Ltd.,
London, Ontario.

for *G. E. Anderson*
Chief, Standards Laboratory,
Standards Branch.

W. J. S. Fraser
W.J.S. Fraser,
Chief, Electricity and Gas Division,
Standards Branch.

Ref: GL 1145-57/C3-57
G 1145-57/C3-57