



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

T-18

OTTAWA August 22, 1966.

NOTICE OF APPROVAL

FOR

CANADIAN WESTINGHOUSE TYPE "KTR" CURRENT TRANSFORMERS

Apparatus

Primary Currents	
Single ratio	200, 300, 400, 500, 600, 800, 1000 and 1200 amperes
Double ratio	400/200, 600/300, 800/400, 1000/500, 1200/600 amperes
Secondary Current	5 amperes
Voltage Rating	600 volts
Accuracy Rating	
200 Amperes	0.3B0.1, B0.2*; 0.6B0.5
300 "	0.3B0.1, B0.2*, B0.5
400 "	0.3B0.1, B0.2, B0.5*; 0.6B0.9
500 "	0.3B0.1, B0.2, B0.5*; 0.6B0.9, B(2x0.9), B1.0
600 "	0.3B0.1, B0.2, B0.5*, B0.9, B1.0; 0.6B(2x0.9), B2.0
800 "	0.3B0.1, B0.2, B0.5, B0.9*, B(2x0.9), B1.0; 0.6B2.0
1000 & 1200 Amperes	0.3B0.1, B0.2, B0.5, B0.9*, B1.0, B(2x0.9), B2.0
Wire	2
Frequency	60Hz
R.F.(rating factor)	
up to 800 amperes	2.0
1000, 1200, 1000/500,	
1200/600 amperes	1.5
Style	Moulded, indoor and outdoor.#

* marked on nameplate. Applies to the particular primary current whether single ratio or part of a dual ratio.

See description.

Description

The transformers covered by this circular are basically the same as those covered by circular S-EA.612. They differ in that the secondary winding of some units is provided with a tap at its centre thus producing a double ratio. They also differ in that the secondary terminal cap has been redesigned so that the transformer may be used outdoors in addition to its indoor use. Units without weatherproof cap are for indoor use only.

...../2