



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-27-3

Ottawa, July 8, 1977

CANADIAN GENERAL ELECTRIC TYPES NC-25, NCL-25,
NCS-25, NCSL-25 CURRENT TRANSFORMERS

Primary Current Ratings	5 ⁽¹⁾ , 10, 15, 25, 40, 50, 75, 100, 150, 200, 300 Amperes
Secondary Current Rating	5A
Accuracy Rating:	
NC-25, NCL-25 (high ratio)	0.3 B-2.0
NCS-25, NCL-25 (low ratio), NCSL-25 (high ratio)	0.6 B-2.0
NCSL-25 (low ratio)	Not approved for revenue metering
Frequency	60 Hz.
Rating Factor (R.F.)	
NC-25, NCL-25	1.5
NCS-25, NCSL-25	2.0
Nominal Voltage Class	25 kV.
Style	Indoor, moulded

(1) 5A primary rating only applies to type NC-25 on the
800 AT structure and to type NCS-25 on the 500 AT structure.

Description

This Notice is a supplement to T-27-2 which remains
in effect. The subject transformers are similar electrically
to those covered by T-27-2. The core and ampere turns are



the same. The principal difference is that the primary terminals are brought off vertically from the top of the unit and the complete unit including the core is moulded in epoxy resin.

Approval granted to:

Canadian General Electric Co.
940 Lansdowne Ave.
Toronto, Ontario

J.L. Armstrong
for J.L. Armstrong, P.Eng.,
Chief, Standards Laboratory,

D.L. Smith
D.L. Smith, P.Eng.,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services

Ref: G 6565-C2-32