


DEPARTMENT OF TRADE AND COMMERCE STANDARDS BRANCH



OTTAWA April 25, 15, 68.

NOTICE OF APPROVAL


FOR

FERRANTI-PACKARD TYPE "LD" 2-WIRE CURRENT TRANSFORMERS

Apparatus

Primary Currents	5, 10, 15, 20, 25, 30, 40, 50, 75, 100, 150, 200, 300, 400, 600, 300, 1000 and 1200 amperes
C	
Secondary Current	5 amperes
Accuracy Rating at 60 hz	0.3B0.1, B0.2; 0.6B0.5 0.3B0.1, B0.2, B0.5, B0.9, B1.0 (0.6B(2x0.9)Note)
	0.3B0.1, B0.2, B0.5, B0.9, B1.0 (0.6B(2x0.9)Note)
R.F. (rating factor)	
1200-5 ratio	1.0
1000-5 ratio	1.25
All others	1.5 (except 600-5A which is 1.33)
Voltage Class	600 volts
Frequency	60 hz
Wire	2
Style	Dry, indoor

- 1 30-5 ratio was not covered by circular S-EA.463
- 2 400-5 and 800-5 ratios covered by circular S-EA.430
- 3 1000-5 and 1200-5 ratios covered by circular S-EA.492
- 4 All ratios except 1000-5 and 1200-5 with serial numbers prior to 2-223000 will be marked with an accuracy rating of either 0.380.2 or 0.680.5
- (5) 1000-5 and 1200-5 ratios will be marked with an accuracy rating of either 0.380.5 or 0.380.9



- 6 All ratios except 1000-5 and 1200-5 with serial numbers 2-223000 and higher will be marked with an accuracy rating of 0.3B0.9. R.F. = 1.5, except 600-5A which has R.F. of 1.33)
- All ratios except 1000-5 and 1200-5 with serial numbers 2-223000 and higher have an accuracy rating of 0.6B(2x0.9) R.F.=1. This will not be marked on the nameplate.

MOTE: A few transformers were manufactured in 1960 with additive polarity, but all transformers manufactured since, have the conventional subtractive polarity.

Description

This circular is a consolidation of 60 hz 2-wire transformers of this type previously covered by circulars S-EA.463, S-EA-480 and S-EA.492 together with transformers of new design with a higher accuracy rating.

All transformers are of the same general appearance having the polarity indicated by white dots moulded adjacent to the corresponding primary bars and secondary terminals.

approval granted to.

Derente-Packard bloc Finites

Tam a

J.S.T. Swanson, Chief, Standards Laboratory, Standards Branch. W.J.S. Fraser, Chief, Electricity and Gas Division, Standards Branch.

W. J. Fraser

Ref. SL-100-866 M