



**NOTICE OF APPROVAL
AVIS D'APPROBATION**

APPROVAL No. - N° D'APPROBATION
T-39-1

Ottawa, 12 June, 1980

CANADIAN GENERAL ELECTRIC TYPE CTPL-5 CURRENT TRANSFORMERS

This constitutes an addition to T-39 which remains in effect, to include the following ratings in the Type CTPL-5:

Primary Currents: 3000/1500, 2000/1000, 1500/750
and 1000/500A

Secondary Currents: 5A

Accuracy Rating:

2000, 3000, 1500, 1000A 0.3 B0.9

750A 0.6 B0.9

500A 0.6 B0.5

Nominal Voltage Class: 600V

Frequency: 60 Hz

Wire: 2

Style: Dry, indoor

Original signed by:

John Armstrong, Acting Chief,
Electricity and Gas Division
LEGAL METROLOGY BRANCH



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

APPROVAL No. - N° D'APPROBATION

T-39-1

Ottawa, le 12 juin 1980

TRANSFORMATEURS DE COURANT GENERAL ELECTRIC, TYPE CTPL-5

Ceci doit être ajouté à l'avis T-39 qui demeure en vigueur, afin d'indiquer les caractéristiques suivantes du type CTPL-5:

Courants primaires:	3000/1500, 2000/1000, 1500/750 et 1000/500A
Courants secondaires:	5A
Précision:	
2000, 3000, 1500, 1000A	0.3 B0.9
750A	0.6 B0.9
500A	0.6 B0.5
Catégorie de tension nominale:	600V
Fréquence:	60 Hz
Fils:	2
Genre:	sec, intérieur

Copie authentique signée par:

John Armstrong, chef intérimaire
Division de l'électricité et du gaz,
Direction de la métrologie légale

Réf: 6565-C3-6