



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-39-1

Ottawa, 12 June, 1980

CANADIAN GENERAL ELECTRIC TYPE CTPL-5 CURRENT TRANSFORMERS

This constitutes an addition to T-39 which remains in effect, to include the following ratings in the Type CTPL-5:

Primary Currents: 3000/1500, 2000/1000, 1500/750  
and 1000/500A

Secondary Currents: 5A

Accuracy Rating:

2000, 3000, 1500, 1000A	0.3 B0.9
750A	0.6 B0.9
500A	0.6 B0.5

Nominal Voltage Class: 600V

Frequency: 60 Hz

Wire: 2

Style: Dry, indoor

John Armstrong, Acting Chief,  
Electricity and Gas Division,  
LEGAL METROLOGY BRANCH.

Ref: G-6565-C2-32