



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-41-1

Ottawa, 22 February 1980

CANADIAN GENERAL ELECTRIC TYPE CM 2.5  
CURRENT TRANSFORMERS

This notice constitutes an addition to T-41 which remains in effect.

It covers the additional rating of 5-5A in the Type CM 2.5.

The accuracy rating is 0.3B0.9 which is marked on the nameplate.

Approval granted to: Canadian General Electric  
Company Limited  
940 Lansdowne Avenue  
Toronto 4, Ontario

J. Armstrong  
Acting Chief  
Electricity and Gas Division  
Legal Metrology Branch

Ref: G 6565-C2-32