

Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL

T-54-2

OTTAWA July 17, 1972

I.T.E. CIRCUIT BREAKER (CANADA) LTD.
TYPE "MC-5" CURRENT TRANSFORMERS
(Made in Canada)

ADDITIONAL CURRENT RATING


Primary Current	400 amperes
Secondary Current	5 amperes
Accuracy Rating at 60 Hz	0.3B0.1, B0.2, B0.5, B0.9* B1.0, B1.8; 0.6B2,0
Frequency	60Hz
R.F. (rating factor)	1.0
Voltage Class	15 kv
Wire	2
Style	Moulded, indoor


* Accuracy rating marked on the nameplate is 0.3B0.9.

This notice is an amendment to T-54-1 which remains in effect.

Approval granted to:

I.T.E. Circuit Breaker
(Canada) Limited,
Eastern Power Devices Division,
Port Credit, Ontario.


J.S.T. Swanson, P. Eng.,
Chief, Standards Laboratory,
Standards Branch.


W.J.S. Fraser,
Chief, Electricity and Gas Division,
Standards Branch.

Ref: SL-100-974 R
1145-57/E4-T13