



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-54-3

Ottawa, February 13, 1978

I.T.E CIRCUIT BREAKER (CANADA)
TYPE MC15A1 CURRENT TRANSFORMERS
MADE IN CANADA

ADDITIONAL CURRENT RATING

Primary Current	2400 Amperes
Secondary Current	5 Amperes
Accuracy Rating at 60H ₂	0.3B0.9, 0.6B1.8
Frequency	60Hz
R.F. (Rating Factor)	1.0
Voltage Class	15kv
Wire	2
Style	Moulded, Indoor

This notice is an addition to T-54-1, -2
which remains in effect.

Approval granted to: I.T.E. Circuit Breaker
(Canada) Limited,
2401 Dixie Road.
Mississauga, Ont.

D.L. Smith
Chief, Electricity & Gas Division
Legal. Metrology Branch.

Ref: G6565-J213