

Department of consumer and corporate affairs / Ministère de la consommation et des corporations

STANDARDS BRANCH DIRECTION DES NORMES

NOTICE OF APPROVAL

T - 62

May 26, 1971 AWATTO

ASEA TYPE "EMFC72" VOLTAGE TRANSFORMERS

Primary Voltage

Secondary Voltage

Ratios

Nominal Voltage Class Accuracy Rating at 60 Hz

Number of Secondaries

Frequency

Style

42000 volts

120 and 70 volts from each secondary

350/600:1, 350/600:1

69 kv

0.3WXY, 0.62, 1.2ZZ; 0.6Z-0.6Z

2, each tapped

60 Hz

Post type, oil insulated, outdoor


- Catalogue number LM 511 046B
- (2) Nameplates are marked 0.3Y, 0.6Z

The metering accuracy rating is 0.3WXY, 0.6Z, 1.2ZZ on either the full winding or the tap, and applies to the secondary when the tertiary winding is not loaded, to the tertiary when the secondary winding is not loaded, and to both windings when the designated burden is divided in any proportion between the two windings, and 0.6Z-0.6Z on either the full winding or the tap applies to the secondary winding when the tertiary winding is loaded with Z burden or vice versa.

Description

The type EMFC72 voltage transformers comprise a base containing the voltage transformer core and windings, and a porcelain insulator on the top of which is an expansion chamber.

Primary connections are clamp type on the top of the hood.



The primary winding is a multi-layer coil of double-enamelled wire with insulation of special paper between the layers which are graded to give even voltage distribution.

The primary grounding terminal is a clamp type, positioned on the outside of the transformer.

Secondary terminals are contained within a terminal box on the side of the base.

Each transformer has two identical tapped secondary windings that produce, with rated primary voltage, 120 volts from terminals X1-X3 and Y1-Y3 and 69.3 volts from terminals X2-X3 and Y2-Y3.

In all cases, the secondary terminal with the lower suffix of the pair has the same polarity as the primary terminal Hl which is on the top of the hood.

Approval granted to:

ASEA Limited, Malton, Ontario.

w.f. J. Frager

J.S.T. Swanson, P. Eng., Chief, Standards Laboratory, Standards Branch. W.J.S. Fraser, Chief, Electricity and Gas Division, Standards Branch.

Ref: SL-100-384 SE-85-18

ASEA TYPE "EMFC72" VOLTAGE TRANSFORMERS

