



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-64-1

Ottawa, January 5, 1978

ASEA TYPE IMBD-145-A2 CURRENT TRANSFORMER

This is an addition to T-64 which remains in effect.

This amendment extends the coverage of T-64 so as to include the following:

<u>Type</u>	<u>Current Rating</u>	<u>Accuracy Rating</u>
IMBD-145-A-	200 x 400-5	0.6B0.5, 0.3B2.0
IMBE-145-A-	300 x 600-5	0.6B0.5, 0.3B2.0

Approval granted to:

ASEA Limited,
Montreal

D.L. Smith, P.Eng.
Chief, Electricity & Gas Division
Legal Metrology Branch

Ref: G-6565-C4-32