



NOTICE OF APPROVAL  
AVIS D'APPROBATION

T-68-1

July 18, 1977

Ottawa, \_\_\_\_\_

I.T.E. INDUSTRIES TYPE "MCB15M" CURRENT TRANSFORMERS

This notice is an addition to T-68 which remains in effect.

It covers an additional rating of 3000/2400-5 amperes for the type MCB15M current transformers.

The accuracy rating for this current rating is 0.3B0.9, 0.6B1.8.

Approval granted to:

I.T.E. Industries Limited,  
2401 Dixie Road,  
Mississauga, Ontario.

*J. L. Armstrong*  
for J. L. Armstrong, P. Eng.,  
Chief, Standards Laboratory,

Metrology and Laboratory Services

*D. L. Smith*  
D.L. Smith, P. Eng.  
Chief, Electricity & Gas Division,

Ref: G 6565-J213-32