



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-75-3

Ottawa, May 7, 1979

FERRANTI-PACKARD TYPE DCCW CURRENT TRANSFORMERS

This Notice constitutes an addition to T-75-2 which remains in effect.

<u>Primary Current</u>	<u>Secondary Current</u>	<u>R.F. (rating factor)</u>	<u>Accuracy Rating at 60Hz</u>
2000	5	1.0	0.3B2.0
1500	5	1.5	0.3B1.0

Frequency 60Hz
 Nominal Voltage C1 0.6kV
 BIL 10 kV
 Style Window type, moulded,
 indoor-outdoor

These transformers are black, and of the same design as those approved under T-75-2 except for the higher primary current ratings and lower R.F. values.

Approval granted to:

Ferranti-Packard Limited,
St. Catharines, Ontario

D.L. Smith,
Chief, Electricity & Gas Division,
Legal Metrology Branch.

Ref: G6565-F2-32