



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

T-76-1

OTTAWA April 7, 1975

**FERRANTI-PACKARD TYPES "KC115" AND "KC138"
CURRENT TRANSFORMERS**

This Notice of Approval constitutes an addition to Approval Notice T-76 of March 22, 1972.

Approval is hereby extended to types "KC115" and "KC138" current transformers (115KV and 138KV class, respectively).

The addition of prefix "C" in the type designation means that the current transformers are intended for use in metering units.

The construction of the "KC115" and the "KC138" is identical to the core and coil units of the "K115" and "K138" approved under circular T-76, except that the long lead required on the "K" type to feed up through the insulator is modified and shortened. The current ratings are the same as in T-76.

Reference is made also to T-14 of July 15, 1966 which covers "KC" types up to the 69KV class.

Approval granted to:

Ferranti-Packard Limited,
St. Catharines, Ontario.

J.L. Armstrong,
Chief, Standards Laboratory,
Metrology and

D.L. Smith,
Chief, Electricity and Gas Division,
Laboratory Services.

Ref: GL 1145-57/F2-50