



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL

T-82

OTTAWA March 5, 1973.

ELECTROMAGNETIC INDUSTRIES TYPES "UMCT", "UCT" AND "U-130" CURRENT TRANSFORMERS

Primary Currents

- UMCT 200, 300, 400, 500, 600, 800 amperes
- UCT 200, 300, 400, 500, 600, 800, 1000, 1200 amperes
- U-130 800, 1000, 1200, 1500, 2000, 2500, 3000, 4000 amperes

Secondary Current

5 amperes

Accuracy Rating at 60 Hz


<u>UMCT</u>	
200, 300 amperes	0.3B0.1, B0.2 [*] ; 0.6B0.5 [*]
400, 500, 600 amperes	0.3B0.1 [*] , B0.2 [*] , B0.5 [*] ; 0.6B0.9
800 amperes	0.3B0.1, B0.2, B0.5, B0.9; 0.6B1.0, B1.8, B2.0
<u>UCT</u>	
200 amperes	0.3B0.1, B0.2 [*]
300 amperes	0.3B0.1, B0.2, B0.5 [*] ; 0.6B0.9
400-500 amperes	0.3B0.1, B0.2, B0.5 [*] , B0.9; 0.6B1.0, B1.8
600 amperes	0.3B0.1, B0.2, B0.5 [*] , B0.9, B1.0; 0.6B1.8
800, 1000, 1200 amperes	0.3B0.1, B0.2, B0.5 [*] , B0.9, B1.0, B1.8; 0.6B2.0
<u>U-130</u>	
800 amperes	0.3B0.1 [*] , B0.2 [*] , B0.5 [*] , B0.9, B1.0; 0.6B1.8, B2.0
1000 amperes	0.3B0.1 [*] , B0.2 [*] , B0.5 [*] , B0.9, B1.0, B1.8; 0.6B2.0 [*]
All others	0.3B0.1, B0.2, B0.5, B0.9, B1.0, B1.8, B2.0

Frequency

60 Hz


R.F. (rating factor)

<u>UMCT</u>	
200 to 600 amperes	2.0
800 amperes	1.5




UMCT

UMCT



U-130



UCT

<u>UCT</u>	
300 to 1000 amperes	2.0
1200 amperes	1.5
<u>U-130</u>	
800 to 2000 amperes	2.0
2500, 3000 amperes	1.5
4000 amperes	1.33
Nominal Voltage Class	600 volts
Wire	2
Style	Window type, moulded, indoor/outdoor

* Accuracy rating marked on the nameplate

Description

These transformers are window type with a single secondary winding wound on a core of grain-oriented steel.

The space around the core and winding is potted with epoxy resin for high mechanical, impact and dielectric strength.

Types UMCT and UCT are equipped with manually-operated short-circuiting devices, type U-130 has none.


Types UMCT and UCT may be supplied with or without a primary bar assembly and with a high or low base.


The primary entrance side is marked "H1" and the secondary terminals are identified by "X1" and "X2" moulded in the body adjacent to their respective terminals with "X1" having the same polarity as "H1".

The nameplate of the type UCT illustrated on page 2 shows a rating factor of 4.0. This will be changed to R.F. 2.0 on units for use in Canada.

Approval granted to:

Electromagnetic Industries, Inc.,
Clearwater, Florida, U.S.A.


J.S.T. Swanson, P. Eng.,
Chief, Standards Laboratory,
Standards Branch.



W.J.S. Fraser
Chief, Electricity and Gas Division,
Standards Branch.

Ref: G 1145-57/E80-155
GL 1145-57/E80-155