



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

T-85-1

Ottawa, August 23, 1978

FERRANTI-PACKARD TYPES "K-115" AND K-138"  
CURRENT TRANSFORMERS

This constitutes an addition to T-85, which remains in effect, to include the Types K-115 and K-138 in the "inverted" design which locates the secondary core(s) and coil(s) in the top part of the transformer.

The nominal voltage class is 115 kV for the K-115 and 138 kV for the K-138.

Reference is made to T-85 for other ratings, data and description.

Approval granted to:

Ferranti-Packard Limited  
St. Catharines, Ontario

D. L. Smith  
Chief,  
Electricity and Gas Division  
Metrology Branch

Ref: G-6565-F2-32