



Consumer and
Corporate Affairs Canada
Legal Metrology

Consommation
et Corporations Canada
Métrologie légale

APPROVAL NO. - N° D'APPROBATION

T-85-2

SEP 12 1984

NOTICE OF APPROVAL

TYPE KX25, KX35, KX46, KX69, KX115 AND
KX138 CURRENT TRANSFORMERS

Applicant: Ferranti Packard Transformers
Limited
P.O. Box 548
St. Catharines, Ontario
L2R 6W9

Manufacturer: Ferranti Packard
Transformers Ltd.
St. Catharines, Ontario

Description: This Notice of Approval
constitutes an addition to T-14, T-76 and
T-85. The current transformers approved
on this notice are similar in construc-
tion to the type K approved on the above
Approval Notices.

The "X" designation indicates that the
current transformers contain a narrow air
gap Type RBX core and coil assembly
approved on T-159.

Condition of Approval: The apparatus
specified herein has been duly approved
under the provisions of the Electricity
Inspection Act R.S.C. 1970, chapter E-4,
and the Electricity Meter Regulations
C.R.C. 1978, chapter 561 for use in
Canada under the general conditions of
the said Regulations, and under any
special conditions listed above.

Reference No.: G6565-F2-32

AVIS D'APPROBATION

TRANSFORMATEURS DE COURANT DES TYPES
KX25, KX35, KX46, KX69, KX115 ET KX138

Requérant: Ferranti Packard Transformers
Limited
P.O. Box 548
St. Catharines, Ontario
L2R 6W9

Fabricant: Ferranti Packard
Transformers Limited
St. Catharines, Ontario

Description: Le présent avis complète
les avis T-14, T-76 et T-85. Les trans-
formateurs de courant approuvés en vertu
du présent avis sont construits de façon
analogue aux transformateurs de type K
approuvés en vertu des avis précités.

La désignation "X" signifie que le
transformateur de courant comprend un
ensemble de type RBX, composé d'un noyau
et d'une bobine à entrefer étroit,
approuvé aux termes de l'avis T-159.

Conditions d'approbation: L'approbation
est accordée en vertu des dispositions
de la Loi sur l'inspection de
l'électricité S.R.C. 1970, chapitre E-4,
et du Règlement sur les compteurs
électriques C.R.C.c. 1978, chapitre 561.
L'emploi est autorisé au Canada sous
réserve des conditions générales dudit
règlement et de toutes les conditions
particulières formulées dans le présent
avis.

N° de référence: G6565-F2-32

J.B. Fulson
for W.R. Virtue

Chief
Legal Metrology Laboratories

SEP 12 1984

Chef
Laboratoires de la Métrologie légale

Canada